

**MINUTES
MARCH 31, 2014**

**PUBLIC HEARING
6:30pm**

Mayor Pardue and all Council Members present. Mayor Pardue called the meeting to order.

PUBLIC HEARING – CDBG APPLICATION

The proposed water systems improvements will further consolidate the Jonesville and Arlington water systems and will meet several current needs for the Jonesville system. The proposed project will increase the Hydraulic Grade Line (HGL) of the entire Jonesville system to match that of the Arlington system and increase service pressure to all of the Jonesville system. This HGL increase will solve documented low pressure concerns and increase available flow for firefighting. The proposed project will also include the replacement of several sections of 2-inch diameter galvanized water mains, upgrade finished water pumps, upgrade water transmission mains, establish reliable pump-free connections between the Jonesville and Arlington systems, and replace a host of residential and commercial meters that currently limit billable water consumption.

R.J. Moseley with McGill Engineering will be present at the meeting to discuss the proposed project and answer any questions.

Council Member Moore made the motion to adopt the resolution that states our intention to apply for funds and to adopt the necessary plans to complete the application process and Council Member Wall, seconded the motion, unanimous 4-0.

No one spoke at the public hearing, so the public hearing was closed.

APPROVAL OF MINUTES

Council Member Moore made the motion to approve the Minutes from March 24, 2014 and March 31, 2014 and Council Member Wall, seconded the motion, unanimous 4-0.

With no pending business to discuss Council Moore made the motion to adjourn and Council Member Wall, seconded the motion, unanimous 4-0.

Mayor, Gene Pardue

Town Clerk, Lynn Trivette